

USERS MANUAL		
BACKFLOW PREVENTER	Fig. 405	Edition: 9/2012 Data: 17.09.2012

CONTENTS

1. Product description
2. Requirement for maintenance staff
3. Transport and storage
4. Function
5. Application
6. Operating principle
7. Assembly
8. Service and repair
9. Valve service discontinuity
10. Warranty terms




Fig. 405

1. PRODUCT DESCRIPTION

The 405 flanged backflow preventers, which have a controllable reduced pressure zone, type BA EN1717, are approved in conformity with EN12729 and are manufactured in accordance with the most severe product norms and in conformity with the quality requirements of EN ISO 9001. They consist of 2 spring check valves and a chamber situated between the spring check valves that contain a security valve, which in the event of “backflow”, isolates the primary network from the user network.

1. Very compact design, one of the smallest backflow preventers, which allows easy installation in limited spaces.
2. Test points fitted with mini-valves, for controlling the absolute and differential pressure in the upstream and intermediate zones. Together with the ECO3 TEST, these allow checking the function of the backflow preventer.
3. Internal and external epoxy coating.
4. Easy maintenance due to removable cover.



2. REQUIREMENTS FOR MAINTENANCE STAFF

The staff assigned to assembly, operating and maintenance tasks should be qualified to carry out such jobs.

3. TRANSPORT AND STORAGE

Keep in a closed and dry place. Avoid exposure to direct sunlight. Protect from moisture and mechanical damage. The temperature of the storage should not exceed -10 ° C to 50 ° C.

4. FUNCTION

Backflow preventer protects the network against the pollution.

5. APPLICATION

Drinking water installations

Temperature: min 0° C max 65° C

Pressure: Dn 65 – 150, 10 Bar


Uwaga: more details in catalogue sheet

6. OPERATING PRINCIPLE

NORMAL OPERATION: REGULAR FLOW


Under normal conditions, the relief valve is closed, and the water flows through the 2 check valves (R1 and R2). Due to the head loss of valve 1, the pressure in the intermediate section is at least 140 millibar less than the upstream pressure.

This difference acts upon the membrane and closes the relief valve.



NO FLOW: NORMAL PRESSURE

The check valves (1 and 2) are closed and the relief valve remains closed.



BACK PRESSURE: DOWNSTREAM OVERPRESSURE

The downstream check valve (R2) closes, preventing potentially contaminated water from flowing into the supply pipe. If the downstream check valve is not perfectly watertight, the polluted water can seep into the central chamber. As the pressure in the central chamber increases, the relief valve opens and the polluted fluid discharges.

BACK-SIPHONAGE: UPSTREAM DEPRESSION

If the upstream pressure accidentally decreases, the check valves (1 and 2) automatically close; so the pressure difference between the upstream section and the central section is reduced; the spring opens the relief valve and the central chamber empties.

Consequently, the flow between the upstream area and the downstream area is interrupted, making it completely safe.

The emptying of the central chamber causes a fall in pressure and brings the valve back to the initial safety conditions.

IMPORTANT: PRIOR TO INSTALLATION

A correct example of how to install the backflow preventer is shown in Fig. A.

1. The device must be located in a common, easily accessible area of the building, it must be ventilated and

not subject to flooding. (The preventer should preferably be placed outside building works and above the soil).

2. The backflow preventer must be located away from every area that may be flooded, always considering the highest level that water may reach in adjacent areas, in case of frequent flooding.

3. Around the device, there must be enough room to enable easy installation or removal.

It must be easily accessible for repair work and working tests.


4. When the device is placed in an installation which may pollute the drinking water supply network, all networks supplying sanitary or food processing systems must be installed upstream with respect to the backflow preventer and the downstream network must be marked with the conventional safety signs and colours, in accordance with UNI 5634P regulations.

5. The opening of the relief valve must enable the water to drain off as a result of gravity.

6. When running a test with the ECO3TEST device, pressure gauges must be at the same height as the backflow, to ensure correct measurement by the differential pressure gauge.


7. The discharge device must not give off toxic fumes into the room. The discharged waters must not be harmful to the environment: the health authorities should be consulted in the cases established by the current regulations.

8. The leakage recovery system, located under the bleed valve mouth, and the discharge water recovery works must have a minimum section, corresponding to the following values:



DN	65	80	100	150
Średnica nominalna:	75/90/120			

CONVEYOR ASSEMBLY



- 1/2. Insert the upper cover 1 into the drain conveyor
3. Fix the cover to the back flow preventer with the plugs included

7. ASSEMBLY


Follow the directions as shown in Fig B.:

1. Install an interception valve x upstream with respect to the backflow preventer.
2. Install an interception valve y downstream with respect to the backflow preventer.
3. When the valves are closed install a strainer with a bleed plug upstream with respect to the preventer, making sure that water flows in the direction indicated on the body.

WARNING

The strainer is essential if the preventer is to work properly. Make sure that, during the installation there are no residual parts in the pipes that may serious damage to the device.


4. Install the backflow preventer between the strainer and the downstream valve, always following the direction indicated on the body
5. Close valves 1-2-3
6. Remove the plastic protection cap located under the bleed valve
7. Fix the bleed pipe
8. Slowly open the upstream valve x
9. Slowly open the preventer valves, in the order 3-2-1, from downstream to up upstream; let them bleed, and close
10. Slowly open the downstream valve y
11. The backflow preventer is now working. Make sure that the relief valve does not leak. In case of leakage, check if there are pressure decreases in the upstream section



8. SERVICE AND REPAIR


MAINTENANCE OF THE RELIEF VALVE

- Unscrew the cap bolts
- Take out and replace the CLOSING DEVICE S




MAINTENANCE OF THE UPSTREAM

- Unscrew the nut and take out the shutter of upstream valve R1
- Replace the seal



MAINTENANCE OF THE DOWNSTREAM

- Take out the upstream valve R2 by acting on the elastic ring
- Unscrew the nut
- Replace the seal



9. VALVE SERVICE DISCONTINUITY

All obsolete and dismantled valves must not be disposed with household waste. ZETKAMA valves are made of materials which can be re-used and should be delivered to designated recycling centres.

10. WARRANTY TERMS

- ZETKAMA grants quality warranty with assurance for proper operation of its products, providing that assembly of them is done according to the users manual and they are operated according to technical conditions and parameters described in ZETKAMA's catalogue cards. Warranty period is 18 months starting from assembly date, however not longer than 24 months from the sales date.

- warranty claim does not cover assembly of foreign parts and design changes done by user as well as natural wear.

- immediately after detection the user should inform ZETKAMA about hidden defects of the product
- a claim should be prepared in written form.

Address for correspondence :

ZETKAMA S.A.
ul. 3 Maja 12 57-410 Ścinawka Średnia
Phone (0048) (74) 8652100
Fax (0048) (74) 8652101
Website: [http:// www.zetkama.com.pl](http://www.zetkama.com.pl)